

Ministry of the Environment, Conservation and Parks - Inspection Summary Rating Record (Reporting Year - 2022-2023)

DWS Name: RIPLEY DRINKING WATER SYSTEM
DWS Number: 220002636
DWS Owner: THE CORPORATION OF THE TOWNSHIP OF HURON-KINLOSS
Municipal Location: HURON-KINLOSS

Regulation: O.REG. 170/03
DWS Category: DW Municipal Residential
Type of Inspection: Focused
Inspection Date: Jul-7-2022
Ministry Office: Owen Sound District Office

Maximum Risk Rating: 466

Inspection Module	Non Compliance Rating
Treatment Processes	0 / 35
Operations Manuals	0 / 28
Water Quality Monitoring	0 / 24
Reporting & Corrective Actions	0 / 4
Other Inspection Findings	14 / 375
Overall - Calculated	14 / 466

Inspection Risk Rating: 3.00%

Final Inspection Rating: 97.00%

Ministry of the Environment, Conservation and Parks - Detailed Inspection Rating Record (Reporting Year - 2022-2023)

DWS Name: RIPLEY DRINKING WATER SYSTEM
DWS Number: 220002636
DWS Owner Name: THE CORPORATION OF THE TOWNSHIP OF HURON-KINLOSS
Municipal Location: HURON-KINLOSS

Regulation: O.REG. 170/03
DWS Category: DW Municipal Residential
Type of Inspection: Focused
Inspection Date: Jul-7-2022
Ministry Office: Owen Sound District Office

Non-Compliant Question(s)	Question Rating
Other Inspection Findings	
Do records confirm that chlorine residual tests are being conducted at the same time and at the same location that microbiological samples are obtained?	14
Overall - Total	14

Maximum Question Rating: 466

Inspection Risk Rating: 3.00%

FINAL INSPECTION RATING: 97.00%