

## **Veolia Water Summary for the Township of Huron-Kinloss**

Date: July 26, 2022 to August 30, 2022

---

### **WATER**

#### **Lakeshore**

Adverse Samples: No adverse bacteriological sample results up to August 22, 2022.

Non-Compliances: None

Equipment Issues: None reported

Mainbreaks and Leaks: 2 water service repairs

Power Outages: None reported

Complaints: 2 water OFF requests, 1 curbstop complaint

Locates: 51 locates up to August 30th (556 YTD)

.

#### **Lucknow**

Adverse Samples: No adverse bacteriological sample results up to August 22, 2022.

Non-Compliances: None

Equipment Issues: None reported

Mainbreaks and Leaks: None

Power Outages: None reported

Complaints: None reported

Locates: 42 locates up to August 30th (100 YTD).

#### **Ripley**

Adverse Samples: No adverse bacteriological sample results up to August 22, 2022.

Non-Compliances: None

Equipment Issues: Ripley Pumphouse High Lift Pump # 1 out of service.

Mainbreaks and Leaks: None

Power Outages: None reported

Complaints: None reported

Locates: 3 locates up to August 30th (80 YTD).

## Veolia Water Summary for the Township of Huron-Kinloss

Date: July 26, 2022 to August 30, 2022

---

### Whitechurch

Adverse Samples: No adverse bacteriological sample results up to August 23rd, 2022.

Non-Compliances: None

Equipment Issues: None reported

Mainbreaks and Leaks: None

Power Outages: None reported

Complaints: None reported

Locates: 2 locates in August (21 YTD).

## WASTEWATER

### Lucknow

Exceedances: No laboratory exceedances. Flows for August are not available at the time of this report. July: daily max 611 m<sup>3</sup> (81 % capacity), daily average 460 m<sup>3</sup> (61 % capacity).

Non-Compliances: None

Equipment Issues: A new aerator is on-site and waiting to be installed when weather permits.

Sewer Main Breaks and Leaks: None

Power Outages: None reported

Complaints: None reported

Total Locates: 42 locates up to August 30th (100 YTD).

## Veolia Water Summary for the Township of Huron-Kinloss

Date: July 26, 2022 to August 30, 2022

---

### WASTEWATER

#### Ripley

Exceedances: Flows for August are not available at the time of this report. July daily max 560 m<sup>3</sup> (93 % capacity), daily average 299 m<sup>3</sup> (50 %).

Non-Compliances: None

Equipment Issues: One sewage pump has been removed from service pending repair/replacement. A spare pump was installed in the interim. Check valves are on-site and ready for installation.

Sewer Main Breaks and Leaks: None

Power Outages: None reported

Complaints: None reported

Total Locates: 3 locates up to August 30th (80 YTD).

### Ongoing Issues/Recommendations

#### Water:

Valve turning is ongoing (approximately 3/4 complete).

#### Wastewater:

Lucknow: Remaining 4 RIBs to be cleaned out and media to be replaced.

Ripley: Check valves to be replaced with new ones.

#### Other:

ACW: 4 locates in August (19 YTD).

During quarterly water meter readings it was noted that 2 water meters in ACW are not functioning. The Township of ACW has been notified and will be contacting a certified meter technician to investigate.

#### COVID:

In response to the COVID-19 pandemic: Operators are conducting daily monitoring of their health and wellness. There is no entry into private residences permitted. Operators are to contact Township staff if they need to access shared spaces. Disinfection protocol is in place for vehicles and work areas, and use of PPE as required. There are no changes to Veolia's policies at this time. Operators are following the Township requirements.