

Veolia Water Summary for the Township of Huron-Kinloss

Date: January 1, 2023 to January 31, 2023

WATER

LAKESHORE

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to Jan 24, however, there were 3 positive Total Coliform results for RAW water: Point Clark Well # 3 - 6 TC on Jan 9, and 2 TC on Jan 24; Murdoch Glen Raw - 1 TC (these are not reportable). No bacteriological samples were collected from the Blairs Grove RAW water since November 21, 2022 (site is offline).

Non-Compliances: Instantaneous flow exceedances at Point Clark on Jan 2 - max flow 41.24 L/s on pump start-up (1 minute duration).

Equipment Issues: Blairs Grove and Huronville sites remained offline for the month of January.

Mainbreaks and Leaks: 1 service leak at the mainstop; 1 curbstop repair, 1 watermain valve was replaced.

Power Outages: None reported at the time of this report.

Complaints / Requests: 5 water turn off requests, 1 water meter removal request (for demolition).

Locates: (see Township master list)

LUCKNOW

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to Jan 24.

Non-Compliances: None

Equipment Issues: None reported at the time of this report.

Mainbreaks and Leaks: 1 service leak.

Power Outages: None reported

Complaints / Requests: 1 curbstop repair, 1 main valve was raised and a repair top was installed.

Locates: (see Township master list)

Veolia Water Summary for the Township of Huron-Kinloss

Date: January 1, 2023 to January 31, 2023

RIPLEY

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to Jan 24.

Non-Compliances: None

Equipment Issues: Ripley Pumphouse offline.

Mainbreaks and Leaks: None

Power Outages: None reported at the time of this report.

Complaints / Requests: 1 emergency water shut-off.

Locates: (see Township master list)

WHITECHURCH

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to Jan 24.

Non-Compliances: None

Equipment Issues: Need a new transfer switch for standby generator (on order).

Mainbreaks and Leaks: None

Power Outages: None reported at the time of this report.

Complaints / Requests: None

Locates: (see Township master list)

WASTEWATER

LUCKNOW

Exceedances: Total Ammonia for the Groundwater Seepage to Swale (GWSS) has returned to normal. Flows for January were not available at the time of this report.

Non-Compliances: None

Equipment Issues: Frozen aerator due to a power interruption tripping the breaker.

Sewer Main Breaks and Leaks: None reported

Power Outages: None reported at the time of this report

Complaints: None

Total Locates: (see Township master list)

Veolia Water Summary for the Township of Huron-Kinloss

Date: January 1, 2023 to January 31, 2023

WASTEWATER

RIPLEY

Exceedances: Flows for January were not available at the time of this report.

Non-Compliances: None

Equipment Issues: One sewage pump has been removed from service pending repair/replacement. A spare pump was installed in the interim. New check valves are at the Ripley Sewage Pump Station - waiting for Cliff's Plumbing to replace faulty check valve.

Sewer Main Breaks and Leaks: None reported

Power Outages: None reported at the time of this report

Complaints: None reported

Total Locates: (see Township master list)

Ongoing Issues/Recommendations

WATER:

Valve turning is on-going.

A new water meter was installed at Sepoy Manor.

WASTEWATER:

Lucknow: Nothing to report.

Ripley: New amended Environmental Compliance Approval will require updates to some procedures.

OTHER:

ACW: Nothing to report.