

# Veolia Water Summary for the Township of Huron-Kinloss

Date: February 1, 2023 to February 28, 2023

---

## WATER

### LAKESHORE

**Adverse Samples:** None

**Microbiological Sampling Summary:** No adverse bacteriological sample results up to Feb 21, however, there was no HPC result on a Blairs Grove Treated sample collected on Feb 13 - it was reported as NDLA (No Data: Laboratory accident/error (sample 10 HPC)). No bacteriological samples have been collected from the Blairs Grove RAW water since November 21, 2022 (site is offline).

**Other Sampling:** First quarter sampling has been completed.

**Non-Compliances:** None

**Equipment Issues:** Blairs Grove and Huronville sites remained offline for the month of January. Monthly SCADA Report for Huronville is not correct - there is an issue with a couple of the new data tags that provide daily values (they are not calculating properly). Contacted Eramosa to correct them.

**Mainbreaks and Leaks:** None reported at the time of this report.

**Power Outages:** None reported at the time of this report.

**Complaints / Requests:** (see Township master list)

**Locates:** (see Township master list)

### LUCKNOW

**Adverse Samples:** None

**Microbiological Sampling Summary:** No adverse bacteriological sample results up to Feb 21.

**Non-Compliances:** None

**Equipment Issues:** None reported at the time of this report.

**Mainbreaks and Leaks:** None reported at the time of this report.

**Power Outages:** None reported

**Complaints / Requests:** (see Township master list)

**Locates:** (see Township master list)

## Veolia Water Summary for the Township of Huron-Kinloss

Date: February 1, 2023 to February 28, 2023

---

### RIPLEY

**Adverse Samples:** None

**Microbiological Sampling Summary:** No adverse bacteriological sample results up to Feb 21.

**Non-Compliances:** None

**Equipment Issues:** Ripley Pumphouse offline.

**Mainbreaks and Leaks:** None

**Power Outages:** Power outage of Feb 1 (RPH generator ran 3.9h, RET generator ran 3.1h)

**Complaints / Requests:** (see Township master list)

**Locates:** (see Township master list)

### WHITECHURCH

**Adverse Samples:** None

**Microbiological Sampling Summary:** No adverse bacteriological sample results up to Feb 21.

**Non-Compliances:** None

**Equipment Issues:** Need a new transfer switch for standby generator (on order).

**Mainbreaks and Leaks:** None

**Power Outages:** None reported at the time of this report.

**Complaints / Requests:** (see Township master list)

**Locates:** (see Township master list)

## WASTEWATER

### LUCKNOW

**Exceedances:** January flows: 1,484 m<sup>3</sup> max daily flow; 789 m<sup>3</sup> avg daily flow (105% capacity).  
February flows were not available at the time of this report.

**Non-Compliances:** None

**Equipment Issues:** None reported at the time of this report.

**Sewer Main Breaks and Leaks:** None reported.

**Power Outages:** None reported at the time of this report

**Complaints:** (see Township master list)

**Total Locates:** (see Township master list)

## Veolia Water Summary for the Township of Huron-Kinloss

Date: February 1, 2023 to February 28, 2023

---

### WASTEWATER

#### RIPLEY

**Exceedances:** January flows: 1,067 m3 max daily flow; 455 m3 avg daily flow (76% capacity).

**Non-Compliances:** None

**Equipment Issues:** One sewage pump has been removed from service pending repair/replacement. A spare pump was installed in the interim. New check valves are at the Ripley Sewage Pump Station - waiting for Cliff's Plumbing to replace faulty check valve.

**Sewer Main Breaks and Leaks:** None reported

**Power Outages:** Power outage Feb 1st

**Complaints:** (see Township master list)

**Total Locates:** (see Township master list)

### Ongoing Issues/Recommendations

#### WATER:

Valve turning is on-going.

#### WASTEWATER:

Lucknow: Nothing to report.

Ripley: New amended Environmental Compliance Approval will require updates to some procedures. There are also new reporting requirements.

#### OTHER:

ACW: Nothing to report.