Date: September, 2023

Prepared by: Sarah Telford/Gary Nicholson

### WATER

\*All sites have regained the ability to print a Monthly Report training has been completed with Eramosa.

## Lakeshore

approximately 100 valves left to turn

Adverse Samples: No adverse bacteriological sample results

Non-Compliances: None.

**Equipment Issues:** 

- Blairs Grove:
- Huronville:
- Scada upgrades ongoing
- Pump motor is being repaired by John Wilsons (bearings)
- Murdock Glen:
  - pump repairs scheduled for the fall
- Point Clark:
  - -Alfred St service leak.

## **General Information:**

- The watermain has been commissioned at Ridgewood
- Flushing has started (working from south to north)
- There is a construction project on London Rd for a new watermain (commissioning samples have been taken)

## Mainbreaks and Leaks:

Amberly Beach and Hillsview Terr. (ACW - Aug 6)

Power Outages: None reported.

**Inquiries and Complaints:** (see Township master list)

Locates: (see Township master list)

## **Lucknow**

**Adverse Samples:** No adverse bacteriological sample results.

Non-Compliances: See the final report from the MECP.

**Equipment Issues:** 

L4L5

Water Tower: ongoing

## **General Information:**

-Routine monthly maintenance was completed



Date: September, 2023

Prepared by: Sarah Telford/Gary Nicholson

-Generator fuel tank replacement at the lift station is scheduled for the end of Sept. 28, 2023.

- Manhole Inspections has started

Alarms: None

Mainbreaks and Leaks: None.

Power Outages: One reported

Inquiries and Complaints: (see Township master list)

Locates: (see Township master list)

# **Ripley**

Adverse Samples: None at the time of this report.

Non-Compliances: None.

**Equipment Issues:** 

• Ripley Well:

Hoppers did well inspection at Well #2

Elevated Tower:

Replacement mixer is installed and operational

### **General Information:**

-Routine monthly maintenance was completed

-Generator fuel tank replacement at the lift station is scheduled for Oct. 4, 2023

-MECP Inspection was received - cleaning of well casing was suggested (planned for 2024)

Alarms: None

Mainbreaks and Leaks: 0 watermain breaks.

Power Outages: One planned outage

Inquiries and Complaints: (see Township master list).

Locates: (see Township master list)

## **Whitechurch**

Adverse Samples: No adverse bacteriological sample results

Non-Compliances: None. Equipment Issues: None.

#### **General Information:**

- -Routine monthly maintenance was completed
- -Lead sampling was completed
- -Quarterly sampling was completed
- -MECP Inspection was received as well as the rating (96.88%)



Date: September, 2023

Prepared by: Sarah Telford/Gary Nicholson

Alarms: None

Mainbreaks and Leaks: None.

Power Outages: None

Inquiries and Complaints: (see Township master list)

Locates: (see Township master list).

OTHER: Nothing at this time

## **WASTEWATER**

### Lucknow

Certificate of Approval = 750m3/day

Exceedances: None

Flows:

August flows: 1047 m<sup>3</sup> max daily flow; 481.17 m<sup>3</sup> avg daily flow(64.16% capacity).

September flows were not available at the time of this report.

Non-Compliances: None Equipment Issues:

• Lift station pump failure - under repair

Sewer Main Breaks and Leaks: None reported.

Power Outages: None reported at the time of this report

**Complaints:** (see Township master list) **Total Locates:** (see Township master list)

### **RIPLEY**

Certificate of Approval = 600m3/day

Exceedances: None

Flows:

August flows: 457 m<sup>3</sup> max daily flow; 333.94 m<sup>3</sup> avg daily flow (56.56% capacity).

September flows were not available at the time of this report.

Non-Compliances: None

**Equipment Issues:** 

• We are working with the MECP for operational assistance to comply with the new ECA.

Sewer Main Breaks and Leaks: None reported

Power Outages: None Reported Complaints: (see Township master list) Total Locates: (see Township master list)



Date: September, 2023

Prepared by: Sarah Telford/Gary Nicholson

# **Ongoing Issues/Recommendations:**

### WATER:

Valve turning is on-going. Fall flushing has begun.

### Murdock Glen

- -Two meters for the transition from Mechanical to MAG Meters has been scheduled to be done with Huronville upgrade.
- -Upgrade for Fuel Tanks has been scheduled for October
- -Leaking seals on pump #5 booked for repairs.

Analyzer Calibrations have been completed.

Sommers completed the Fall generator maintenance.

## **WASTEWATER:**

**Lucknow**: Nothing to report. **Ripley**: Nothing to report

Check Valve replacement has been rescheduled for October due to weather.

New amended Environmental Compliance Approval will require updates to some procedures.

There are also new reporting requirements.

