

Veolia Water Summary for the Township of Huron-Kinloss

Date: August, 2023

Prepared by: Sarah Telford/Gary Nicholson

WATER

**All sites have lost the ability to print a Monthly Report due to Eramosa programming issues - training has been scheduled with Eramosa.*

Lakeshore

approximately 100 valves left to turn

Adverse Samples: No adverse bacteriological sample results

Non-Compliances: None.

Equipment Issues:

- **Blairs Grove:**
- **Huronville:**
 - Pump motor is being repaired by John Wilsons (bearings)
- **Murdock Glen:**
 - pump repairs scheduled for the fall
- **Point Clark:**

General Information:

- Quarterly sampling was completed
- Lead sampling was completed (July)

Mainbreaks and Leaks:

Power Outages: None reported.

Inquiries and Complaints : (see Township master list)

Locates: (see Township master list)

Lucknow

Adverse Samples: No adverse bacteriological sample results.

Non-Compliances: See the final report from the MECP.

Equipment Issues:

- **L4**
- **L5**
 - Upgrade for a frequency drive on the well pump completed

Water Tower: ongoing

General Information:

- Routine monthly maintenance was completed
- Quarterly sampling was completed
- Lead sampling was completed (July)

Veolia Water Summary for the Township of Huron-Kinloss

Date: August, 2023

Prepared by: Sarah Telford/Gary Nicholson

Alarms: None

Mainbreaks and Leaks: None.

Power Outages: None

Inquiries and Complaints: (see Township master list)

Locates: (see Township master list)

Ripley

Adverse Samples: 1 TC in the distribution , resamples were all clear.

Non-Compliances: None.

Equipment Issues:

- **Ripley Well:**
 - Hoppers did well inspection at Well #2
- **Elevated Tower:**
 - Replacement mixer is received and ready to install

General Information:

- Routine monthly maintenance was completed
- Lead sampling was completed
- Quarterly sampling was completed
- MECP Inspection is in progress

Alarms: None

Mainbreaks and Leaks: 0 watermain breaks.

Power Outages: None

Inquiries and Complaints: (see Township master list).

Locates: (see Township master list)

Whitechurch

Adverse Samples: No adverse bacteriological sample results

Non-Compliances: None.

Equipment Issues: None.

General Information:

- Routine monthly maintenance was completed
- Lead sampling was completed
- Quarterly sampling was completed
- MECP Inspection is in progress

Alarms: None

Veolia Water Summary for the Township of Huron-Kinloss

Date: August, 2023

Prepared by: Sarah Telford/Gary Nicholson

Mainbreaks and Leaks: None.

Power Outages: None

Inquiries and Complaints: (see Township master list)

Locates: (see Township master list).

OTHER: Nothing at this time

WASTEWATER

Lucknow

Certificate of Approval = 750m³/day

Exceedances:None

Flows:

July flows: 682 m³ max daily flow; 439.29 m³ avg daily flow(58.57% capacity).

August flows were not available at the time of this report.

Non-Compliances: None

Equipment Issues:

- Lift station pump failure - under repair

Sewer Main Breaks and Leaks: None reported.

Power Outages: None reported at the time of this report

Complaints: (see Township master list)

Total Locates: (see Township master list)

RIPLEY

Certificate of Approval = 600m³/day

Exceedances: None

Flows:

July flows: 654 m³ max daily flow; 342.16 m³ avg daily flow (57.02% capacity).

August flows were not available at the time of this report.

Non-Compliances: None

Equipment Issues:

- We are working with the MECP for operational assistance to comply with the new ECA.

Sewer Main Breaks and Leaks: None reported

Power Outages: None Reported

Complaints: (see Township master list)

Total Locates: (see Township master list)

Veolia Water Summary for the Township of Huron-Kinloss

Date: August, 2023

Prepared by: Sarah Telford/Gary Nicholson

Ongoing Issues/Recommendations:

WATER:

Valve turning is on-going.

Fall flushing has been scheduled.

Murdock Glen

- Two meters for the transition from Mechanical to MAG Meters has been scheduled to be done with Huronville upgrade.
- Upgrades are required for Fuel Tanks
- Leaking seals on pump #5 - booked for repairs.

Analyzer Calibrations have been completed.

Sommers completed the Fall generator maintenance.

WASTEWATER:

Lucknow: Nothing to report.

Ripley: Nothing to report

Check Valve replacement has been rescheduled to September due to weather.

New amended Environmental Compliance Approval will require updates to some procedures.

There are also new reporting requirements.