

Veolia Water Summary for the Township of Huron-Kinloss

Date: August, 2024

Prepared by: Sarah Telford

WATER

Lakeshore

Adverse Samples: No adverse bacteriological sample results

Non-Compliances: None.

Equipment Issues:

- **Blairs Grove(BG):**
 - Nothing to report
- **Huronville(HV):**
 - Generator is on order
- **Murdoch Glen(MG):**
 - Nothing to report
- **Point Clark (PC):**
 - Nothing to report

General Information:

Working on all required Work Orders and all samples were taken including Lead

- 700 Victoria Rd survey completed (the well is on private property)
- Flushing is complete on schedule to start the fall flushing
- Valve turning has been completed
- Meter at Elliots to be installed by Kemptons
- Calibrations of online Analyzers completed
- Annual generator inspections completed
- London Rd old watermain has been disconnected
- SAI Re Accreditation Audit is scheduled for Aug 27th.

Alarms:

- Huronville -
- Point Clare
- Huronville

Main Breaks and Leaks:

- None

Power Outages:

- None

Inquiries and Complaints :

- Emergency water shut-off at 807 Park Place
- Water turn on at 162 Bruce St

Locates: (see Township master list)

Veolia Water Summary for the Township of Huron-Kinloss

Date: August, 2024

Prepared by: Sarah Telford

Lucknow

Adverse Samples:

- None

Non-Compliances:

- None

Equipment Issues:

- **L4**
 - water line in well house leaking, repaired
- **L5**
 - None

Water Tower:

- Nothing to report

General Information:

Working on Work Orders and all samples were taken including Lead

- Valve turning completed
- Annual generator inspections completed
- 1 Tie-in has been completed for the Wheeler St project
- The MECP Inspections was received and was awarded 100%

Alarms:

- None

Main breaks and Leaks:

- None to Report

Power Outages:

- None to Report

Inquiries and Complaints:

- Emergency water shut off at 572 Campbell St

Locates: (see Township master list)

- a new software program has been initiated for locates

Ripley

Adverse Samples: None.

Non-Compliances: None.

Equipment Issues: None.

Alarms: None

Veolia Water Summary for the Township of Huron-Kinloss

Date: August, 2024

Prepared by: Sarah Telford

- **Ripley Well:**
 - Well #2 MCC replacement is completed, issue with neutral on generator, waiting on Eromosa
- **Elevated Tower:**
 - John requests that Veolia adds the Tower generator to our monthly testing schedule

General Information:

Working on Work Orders and all samples were taken including Lead

- Manhole repairs have been completed by SGS
- Flushing has been completed, duplicate hydrants on the GIS mapping system need to be removed
- backflow preventers inspected
- online analyzers calibrated
- Annual generator inspections were completed
- Ripley Inspection is underway

Alarms:

- None reported

Main breaks and Leaks:

- None

Power Outages:

- None

Inquiries and Complaints: None reported.

Locates: (see Township master list)

Whitechurch

Adverse Samples: No adverse bacteriological sample results

Non-Compliances:

- None.

Equipment Issues:

- None to report.

General Information:

Working on Work Orders and all samples were taken including Lead

- Fuel tank has been inspected, waiting for report-keep calling for report and update, waiting to hear back
- MECP Inspection was received and awarded a 96.59%
 - there was 1 nonconformance (see report)
 - Also a typo was noted in the Annual report (Sarah will reissue the report with corrections made)
- Annual generator inspections completed

Veolia Water Summary for the Township of Huron-Kinloss

Date: August, 2024

Prepared by: Sarah Telford

Alarms: None

Main breaks and Leaks:

- None reported.

Power Outages:

- None to report

Inquiries and Complaints: (see Township master list)

- None to report

Locates: (see Township master list)

WASTEWATER

Lucknow WW

Certificate of Approval = 750m³/day

Exceedances: flows

Flows:

- July flows: 615 m³ max daily flow; 477.58m³ avg daily flow (63.68% capacity)

Non-Compliances: None

Equipment Issues:

- Check valve for pump #3 at LLS has been approved to order
- Air release valve has been ordered
- Investigating effluent pump floats at the Lucknow Lagoon (probable replacement needed)

General information:

- RIB repairs have been completed
- RIBs are being rotated to try and keep the duckweed minimal Cell 6 is still a problem-John to order material
- Annual generator inspections happening into August
- Alum delivery July 31

Sewer Main Breaks and Leaks: None reported.

Power Outages:

-

Complaints: (see Township master list)

Total Locates: (see Township master list)

RIPLEY WW

Certificate of Approval = 600m³/day

Exceedances: None

Flows:

- May flows: 405 m³ max daily flow; 249.94 avg daily flow (41.66% capacity).

Non-Compliances: None

Veolia Water Summary for the Township of Huron-Kinloss

Date: August, 2024

Prepared by: Sarah Telford

Equipment Issues: None

General information:

- We are keeping the alum treatment higher to avoid the large dosing prior to discharges
- BMRoss looking at dumping station options to limit chances of spills and danger to operators-John to line up Kemptons to do construction once approved
- ECA has been submitted for approval
- Annual generator inspections was completed

Alarms:

- None

Sewer Main Breaks and Leaks: None reported

Power Outages:

- None

Complaints: (see Township master list)

Total Locates: (see Township master list)

Ongoing Issues/Recommendations:

WATER:

Crane/ hoist /harness Inspections booked for September

Flow meters rescheduled and analyzer calibrations completed

Valve turning has started

Flushing:

- Request to have weeds/tree growth cleared around the well heads/buildings also the fire hydrants on Lake range
- John to have the GIS mapping updated as there are duplicates

Hydrant markers will be changed out with each seasons' flushing (on for winter, off for summer)

WASTEWATER:

Lucknow: Need to get grass cut around Lagoons

Ripley: Nothing new to report.