

# Veolia Water Summary for the Township of Huron-Kinloss

Date: September, 2024

Prepared by: Sarah Telford

---

## WATER

### Lakeshore

**Adverse Samples:** No adverse bacteriological sample results

**Non-Compliances:** None.

**Equipment Issues:**

- **Blairs Grove(BG):**
  - Nothing to report
- **Huronville(HV):**
  - Generator is on order
- **Murdoch Glen(MG):**
  - Nothing to report
- **Point Clark (PC):**
  - Sommers repaired the standby generator

**General Information:**

*Working on all required Work Orders and all samples were taken including Lead*

- 1 of 2 blow offs at Victoria and Lighthouse needs to be removed as 1 has been abandoned

**Alarms:**

- Huronville - Chlorine pump fail (8th)
- Point Clark -Chlorine pump 3 and 4 fail (9th)
  
- Blairs Grove -none
- Murdoch Glen -none

**Main Breaks and Leaks:**

- None

**Power Outages:**

- None

**Inquiries and Complaints :**

**Locates:** (see Township master list)

### Lucknow

**Adverse Samples:**

- None

**Non-Compliances:**

- None

# Veolia Water Summary for the Township of Huron-Kinloss

Date: September, 2024

Prepared by: Sarah Telford

---

## Equipment Issues:

- **L4**
  - None
- **L5**
  - None

## Water Tower:

- Nothing to report

## General Information:

*Working on Work Orders and all samples were taken including Lead*

West and East Watermain has been connected at the Wheeler St Watermain Project.

## Alarms:

- None

## Main breaks and Leaks:

- None to Report

## Power Outages:

- None to Report

## Inquiries and Complaints:

-

**Locates:** (see Township master list)

- a new software program has been initiated for locates

## Ripley

**Adverse Samples:** None.

**Non-Compliances:** None.

**Equipment Issues:** None.

**Alarms:** None

- **Ripley Well:**
  - Well #2 MCC replacement to be completed by Belwood
- **Elevated Tower:**
  - John requests that Veolia adds the Tower generator to our monthly testing schedule

## General Information:

*Working on Work Orders and all samples were taken including Lead*

- **AAlarms:**
  - None reported

## Main breaks and Leaks:

- None

## Veolia Water Summary for the Township of Huron-Kinloss

Date: September, 2024

Prepared by: Sarah Telford

---

### Power Outages:

- None

**Inquiries and Complaints:** None reported.

**Locates:** (see Township master list)

### Whitechurch

**Adverse Samples:** No adverse bacteriological sample results

**Non-Compliances:**

- None.

**Equipment Issues:**

- None to report.

**General Information:**

*Working on Work Orders and all samples were taken including Lead*

- Fuel tank has been inspected, waiting for report-keep calling for report and update, waiting to hear back
- 

**Alarms:** None

**Main breaks and Leaks:**

- None reported.

**Power Outages:**

- None to report

**Inquiries and Complaints:** (see Township master list)

- None to report

**Locates:** (see Township master list)

## WASTEWATER

### Lucknow WW

Certificate of Approval = 750m<sup>3</sup>/day

**Exceedances:** flows

**Flows:**

- August flows: 673 m<sup>3</sup> max daily flow; 315 m<sup>3</sup> avg daily flow (42% capacity)

**Non-Compliances:** None

**Equipment Issues:**

- Check valve for pump #1 at LLS has been installed by Caldecott
- Investigating effluent pump floats at the Lucknow Lagoon (probable replacement needed)

# Veolia Water Summary for the Township of Huron-Kinloss

Date: September, 2024

Prepared by: Sarah Telford

---

- Aerator #3 burnt out and was replaced but started to smoke when put in service -Marcus is Investigating further to find the issue.

## General information:

- The grass needs to be cut down around the winter storage

**Sewer Main Breaks and Leaks:** None reported.

**Power Outages:**

-

**Complaints:** (see Township master list)

**Total Locates:** (see Township master list)

## RIPLEY WW

Certificate of Approval = 600m<sup>3</sup>/day

**Exceedances:** None

**Flows:**

- May flows: 307 m<sup>3</sup> max daily flow; 231 avg daily flow (38.50% capacity).

**Non-Compliances:** None

**Equipment Issues:**

- The air release at RLS was replaced

**General information:**

- We are keeping the alum treatment higher to avoid the large dosing prior to discharges
- BMRoss looking at dumping station options to limit chances of spills and danger to operators-John to line up Kemptons to do construction once approved

**Alarms:**

- None

**Sewer Main Breaks and Leaks:** None reported

**Power Outages:**

- None

**Complaints:** (see Township master list)

**Total Locates:** (see Township master list)

## Ongoing Issues/Recommendations:

### WATER:

Crane/ hoist /harness Inspections booked for September

Flow meters rescheduled and analyzer calibrations completed

Valve turning has started

Flushing:

- Zone 2 has been completed
- Request to have weeds/tree growth cleared around the well heads/buildings also the fire hydrants on Lake range

## Veolia Water Summary for the Township of Huron-Kinloss

Date: September, 2024

Prepared by: Sarah Telford

---

- John to have the GIS mapping updated as there are duplicates
- There are appr. 24 Hydrants/blow offs that need to be pumped out before winter  
*Hydrant markers will be changed out with each seasons' flushing (on for winter, off for summer)*

### **WASTEWATER:**

**Lucknow:** Need to get grass cut around Lagoons

**Ripley:** Nothing new to report.