

Veolia Water Summary for the Township of Huron-Kinloss

Date: November, 2024

Prepared by: Sarah Telford

WATER

Lakeshore

Adverse Samples: No adverse bacteriological sample results

Non-Compliances: None.

Equipment Issues:

- **Blairs Grove(BG):**
 - Nothing to report
- **Huronville(HV):**
 - Is supporting Kincardine with water starting Nov. 26.
- **Murdoch Glen(MG):**
 - Nothing to report
- **Point Clark (PC):**
 - Nothing to report

General Information:

Work Orders were completed and all regulatory samples were taken

- 1 of 2 blow offs at Victoria and Lighthouse needs to be removed as 1 has been abandoned

Alarms: None to report

Main Breaks and Leaks: None

Power Outages: None

Inquiries and Complaints : None

Locates: (see Township master list)

Lucknow

Adverse Samples: None

Non-Compliances: None

Equipment Issues:

- **L4**
 - Roof needs to be replaced
- **L5**
 - Floor piping should be replaced or refurbished - it is badly corroded

Water Tower: Nothing to report

General Information:

Work Orders were completed and all regulatory samples were taken

Alarms: None

Main breaks and Leaks: None to Report

Veolia Water Summary for the Township of Huron-Kinloss

Date: November, 2024

Prepared by: Sarah Telford

Power Outages: None to Report

Ripley

Adverse Samples: None.

Non-Compliances: None.

Equipment Issues: None.

Alarms: None

- **Ripley Well:**
 - Nothing to report
- **Elevated Tower:**
 - Nothing to report

General Information:

Work Orders were completed and all regulatory samples were taken

Alarms: None reported

Main breaks and Leaks: None

Power Outages: None

Whitechurch

Adverse Samples: No adverse bacteriological sample results

Non-Compliances: None.

General Information:

Working on Work Orders and all samples were taken including Lead

- Fuel tank has been inspected, waiting for a decision on quotes for replacement.

Equipment Issues: None to report.

Alarms: None

Main breaks and Leaks: None reported.

Power Outages: None to report

WASTEWATER

Lucknow WW

Certificate of Approval = 750m³/day

Exceedances: flows

Flows:

- October flows: 611 m³ max daily flow; 451.55m³ avg daily flow (60.21% capacity)

Non-Compliances: None

Equipment Issues:

- Check valve for pump #1 at LLS has been installed by Caldecott
- Investigating effluent pump floats at the Lucknow Lagoon (probable replacement needed)
- Lift station - need to pull the pump and clean out the wet well.

Veolia Water Summary for the Township of Huron-Kinloss

Date: November, 2024

Prepared by: Sarah Telford

General information:

- Nothing to report

Sewer Main Breaks and Leaks: None reported.

Power Outages: None to report

RIPLEY WW

Certificate of Approval = 600 m³/day

Exceedances: None

Flows:

- October flows: 290 m³ max daily flow; 197.90m³ avg daily flow (32.99% capacity).

Non-Compliances: None

Equipment Issues:

- None reported

General information:

- The alum treatment is being kept higher than previously to avoid the large dosing prior to discharges
- BMRoss looking at dumping station options to limit chances of spills and danger to operators-John to line up Kemptons to do construction once approved
- PW Dept to spray at the aeration cell

Alarms: None

Sewer Main Breaks and Leaks: None reported

Power Outages: None

Ongoing Issues/Recommendations:

WATER:

All Inquiries, Complaints and locates are looked after by the Township.

- Veolia requests to have weeds/tree growth cleared around the well heads/buildings and the fire hydrants on Lake range
- John to have the GIS mapping updated as there are duplicates
- Power was out on Oct 31 in Ripley. Showing that there is still a problem with alarm dialer. Caller should be back up to SCADA not in addition to. John working with Scott Lillie re: repair costs.

WASTEWATER:

Lucknow: Nothing to report

Ripley: Nothing new to report.