

Huron Kinloss Monthly Report 2025

February

Callouts

Feb 6- Ripley tower communication alarm

Feb 9- Low Chlorine alarm – low chlorine in reservoir – working with scada to have the reservoirs run on a regular basis to keep chlorine more consistent

Feb 17-Point Clark Chlorine pump fail alarm

Feb 18- water main break Ripley—Repaired by Kempton's. Boiled water advisory was put in place due to not being able to test residual on night of repair due to weather. Sample taken and all clear; water boiled advisory was lifted February 21.

Feb 25- ATS (Automatic transfer switch) failed at tower. Operator on site to meet with Sommers generator (on-going)

Operational

-**Feb 7-** Kempton's on site for water leak at Alfred st on Lakeshore. Old 2-inch water line was capped.

-**Feb 13** – Hydrant hit by plow- Kemptons scheduled to do repair.

-26 locates

-Training for locates with Utilocate was completed with operators