

Ontario Clean Water Agency Summary for the Township of Huron-Kinloss

Date: Month of March 2025

WATER

LAKESHORE

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to March 19, 2025. Scheduled 15.1 samples taken. (Lead and Alkalinity)

Equipment Issues: Blairs Grove sites remained offline for the month of March until reservoir is emptied and refilled with potable water.

Mainbreaks and Leaks: Nothing to report.

Power Outages: Power outages at Point Clark stand pipe. Power outages at Huronville. Both due to high winds.

Complaints / Requests: Nothing to report.

Locates: (see Township master list)

LUCKNOW

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to March 19 2025. Scheduled 15.1 samples taken. (Lead and Alkalinity)

Non-Compliances: None

Equipment Issues: None reported at the time of this report.

Mainbreaks and Leaks: 1 service leak.

Power Outages: None reported

Complaints / Requests: 2 water shut offs for repairs.

Locates: (see Township master list)

Ontario Clean Water Agency Summary for the Township of Huron-Kinloss

Date: Month of March 2025

RIPLEY

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to March 19 2025. Scheduled 15.1 samples taken. (Lead and Alkalinity)

Non-Compliances: None

Equipment Issues: Auto transfer switch failed at water tower. Sommers on site to repair.

Mainbreaks and Leaks: None

Power Outages: None reported at the time of this report.

Complaints / Requests: Complaint for discolored water. This was during large fire in Ripley, spoke with homeowner. Mentined to run taps for a few minutes and will clear up. Customer was happy with our conversation.

Locates: (see Township master list)

WHITECHURCH

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to March 19, 2025. Scheduled 15.1 samples taken. (Lead and Alkalinity)

Non-Compliances: None

Equipment Issues: Nothing to Report.

Mainbreaks and Leaks: None

Power Outages: None reported at the time of this report.

Complaints / Requests: None

Locates: (see Township master list)

WASTEWATER

LUCKNOW

Exceedances: Overflow at lagoon was reported due to high flows. Diverted waste to storage tank until lagoons lower.

Non-Compliances: In February TSS was exceeded. TSS due to mis-sampling.

Equipment Issues: Electrician on site to quote replacing pump at lagoon. **Sewer Main Breaks and Leaks:** None reported

Power Outages: None reported at the time of this report

Ontario Clean Water Agency Summary for the Township of Huron-Kinloss

Date: Month of March 2025

WASTEWATER

RIPLEY

Exceedances: Nothing to report.

Non-Compliances: None

Equipment Issues: Sewage pump failed, had been removed and replaced with rebuilt. Will send failed pump in for quote to have rebuilt.

Sewer Main Breaks and Leaks: None reported

Power Outages: None reported at the time of this report

Complaints: None reported

Total Locates: (see Township master list)

Ongoing Issues/Recommendations

WATER:

Spring flushing will begin in April and removal of hydrant flags.

WASTEWATER:

Lucknow: Have sewage pump installed.

Ripley: Start Discharging last week of March.

OTHER:

ACW: Nothing to report.