

Ontario Clean Water Agency Summary for the Township of Huron-Kinloss

Date: Month of April 2025

WATER

LAKESHORE

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to April 28, 2025.

Equipment Issues:

- Blairs Grove sites remained offline for the month of April. Reservoir will be emptied and refilled with potable water, as the well has not been used in a long time and residuals are dropping.
- Point Clark high lift pump 1 faulted April 27, alarm dialer did not call out causing low pressure. Operator received call from municipality about customers concerned with low pressure. Operator went online and noticed that SCADA was alarming but did not call out. Reset high lift pump and system is now running normal. ERAMOSA is currently investigating dialler issues
- Murdoch Glen has had two pressure issues in early April. Pressure is now ok. Weekly monitoring is currently being tracked by Township staff.
-

Main breaks and Leaks: Nothing to report.

Power Outages: Power outages due to weather, April 2 and April 7.

Complaints / Requests: Low-pressure complaint on Lakeshore Drive. Flush hydrants, pressure normal.

Locates: (see Township master list)

LUCKNOW

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to April 21, 2025.

Non-Compliances: None

Equipment Issues: None reported at the time of this report.

Main breaks and Leaks: Nothing to report.

Power Outages: Nothing to report

Complaints / Requests: Nothing to report

Locates: (see Township master list)

Ontario Clean Water Agency Summary for the Township of Huron-Kinloss

RIPLEY

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to April 28, 2025.

Non-Compliances: None

Equipment Issues: Auto transfer switch failed at water tower. Sommers on site to repair, April 11.

Main breaks and Leaks: None

Power Outages: Power outages due to weather, April 2

Complaints / Requests: Low pressure complaints south of Ripley. Pressure normal on Scada. Flushed hydrants and tested pressure. All pressures are normal reading between 50-60psi

Locates: (see Township master list)

WHITECHURCH

Adverse Samples: None

Microbiological Sampling Summary: No adverse bacteriological sample results up to April 28, 2025.

Non-Compliances: None

Equipment Issues: Low pressure alarm, SCADA did not call out for alarms. Flushed system, samples taken, all normal. ERAMOSA is currently investigating dialler issues

Main breaks and Leaks: None

Power Outages: Power outages April 2 due to weather.

Complaints / Requests: None

Locates: (see Township master list)

Ontario Clean Water Agency Summary for the Township of Huron-Kinloss

WASTEWATER

LUCKNOW

Exceedances: Nothing to report.

Non-Compliances: Nothing to report.

Equipment Issues: Electrician looking into parts to get pump #2 installed and working at lagoon.

Sewer Main Breaks and Leaks: Nothing to report.

Power Outages: Power outages due to weather, April 2

Total Locates: (see Township master list)

WASTEWATER

RIPLEY

Exceedances: Nothing to report.

Non-Compliances: None

Equipment Issues: Pump sent away for quote to be rebuilt., Operator Monitoring raising flow levels. Called in Vac truck to divert wastewater to lagoon.

Sewer Main Breaks and Leaks: None reported

Power Outages: Power outages due to weather, April 2

Complaints: None reported

Total Locates: (see Township master list)

Ongoing Issues/Recommendations

WATER:

Spring flushing started on Lakeshore April 23 – ongoing.

WASTEWATER:

Lucknow: Waiting for electrician to source parts for pump install at lagoon.

Ripley: Discharging last week of April. Discharging ends April 30th

OTHER:

ACW: Nothing to report.